A T-KJr. with Storage Tank

QTY	Basic Application Specs.
1	T-KJr.
1	TK-TV03
1	TK-RE01 Optional
1	Recir. Pump Required



Takagi USA

3-B Goodyear
Irvine, CA 92618
Phone: (888) 882-5244
Fax: (949) 770-3171
www.Takagi-USA.com

Note: This drawing is intended as a basic guide. Local and State Codes dictate correct installation .
Each individual application, pump size, and gas pipe diameter must be sized correctly.

	Recirculation Pump Min. 1/12 Hp		Pressure Only Relief Valve		Min. Ø 3/4" Gas Shut-off Ball Valve
	Water Shut-off Ball Valves		Unions		Check Valves